



CHULA VISTA FIRE DEPARTMENT

FIRE PREVENTION DIVISION

FIRE LANE IDENTIFICATION

Detail A - Fire Lane Identification - No Stopping Sign



Notes:

- Signs shall be in accordance with Caltrans/FHWA standard [R26F]
- Signs shall include appropriate CVC section [22500.1]
- The face of the sign shall be parallel to the roadway
- Spaced at maximum intervals of 50ft on center or fraction thereof
- Signs shall be mounted on posts 7ft above grade

Detail B - Fire Lane Identification - Curb Painting



Notes:

- Entire curb shall be painted red [two coats]
- White lettering - "FIRE LANE - NO STOPPING" [two coats]
- Lettering height - minimum of 4 inches
- Lettering to be on top of designated curbing
- Spaced at maximum intervals of 25ft on center or fraction thereof

Detail C - Fire Lane Identification - Striping (with no curb)

FIRE LANE - NO STOPPING

Notes:

- Minimum width of this red stripe shall be 8 inches [two coats]
- White lettering - "NO STOPPING - FIRE LANE" [two coats]
- Lettering height - minimum of 6 inches
- Spaced at maximum intervals of 25ft on center or fraction thereof

